

Technical Bulletin Cleaning of Kentec control panels

In the current situation to prevent the spread of Coronavirus Covid-19 it has never been more important to ensure that surfaces are kept clean. This includes our fire alarm control panels which have controls and touch screens used by engineers and end users when operating them.

As with all electronic equipment we must be careful regarding the materials used to clean them, therefore we have produced a Technical Instruction Document, TID1002 included with this bulletin, with our recommendations for cleaning all of our range or control panels.

We would appreciate that these recommendations be adhered to ensuring no damage to the operation or functionality of our life safety products. Kentec can take no liability for any damage that may be caused to our products by not following the laid out recommendations.

Should you require technical assistance on any of our products please contact our technical support team.

We wish all our customers and their families the best of health in this difficult time.

Regards,

Philip J Barton
Commercial Product Manager



Cleaning

Kentec Electronics Control Panels

Date: April 7, 2020

Keeping your Kentec Electronics Control Panel clean is a function that periodically should be carried out to ensure the product is free from dust and dirt. By product group, the following information provides details on how to clean the Control Panel and what materials to use:

Product	Method
K3000 Control Panel	Gently clean using a soft dry cloth to remove dust and dirt.
K3200 Repeater	If the enclosure is heavily contaminated, moisten the cloth
Sigma	and gently clean using a light detergent.
Sigma CP/Sigma CP-R	Important! Avoid getting detergent on controls section of the Control Panel.

Product	Method
Solo/Solo 2/Solo 2 Lite	Gently clean using a soft dry cloth to remove dust and dirt.
Solo/Solo 2 Repeater	If the enclosure is heavily contaminated, moisten the cloth
Syncro/Syncro Response/	 and gently clean using a light detergent. Important! Avoid getting detergent on controls section of the Control Panel.
Syncro Focus	
Syncro AS	

Kentec Electronics Extinguishant Control Panels and Ancillaries (All versions)		
Product	Method	
Solex	Gently clean using a soft dry cloth to remove dust and dirt.	
Sigma XT /Sigma XT+	If the enclosure is heavily contaminated, moisten the cloth and gently clean using a light detergent.	
K Series Extinguishant Control Panels (E.g. K2.01)		
Syncro XT/Syncro XT+/	Important! Avoid getting detergent on controls section of the Control Panel.	
Syncro XT+ Coincidence		

TID-1002 Rev.01 Page 1 of 2



Cleaning

Kentec Electronics Control Panels

Cleaning the Touch Screen Display	The touch screen display is made of fragile materials. Do not apply excessive force to the display surface since this may cause damage. A polariser covering the display surface is soft and easily scratched therefore do not operate the display with items harder than, for example a HB pencil. If the display is damaged causing liquid crystal substance to leak, any contact with skin or clothes, wash thoroughly with soap and water. If the display surface becomes dirty gently wipe with a soft dry cloth. If the display is heavily contaminated, moisten the cloth and gently clean using one of the following solvents: Isopropyl alcohol Ethyl alcohol
Cleaning the Control Panel	Gently clean using a soft dry cloth to remove dust and dirt.
Enclosure	If the enclosure is heavily contaminated, moisten the cloth and gently clean using a light detergent.
	Important! Avoid getting detergent on controls section of the Control Panel.

TID-1002 Rev.01 Page 2 of 2