

Sigma CP

Sigma Doc Box
Fire Alarm Document Box
Installation and Use

Australia Version 1.1 July 2012

Installation

The document box is styled to match the Incite Sigma range of fire alarm and control equipment.

It should be mounted on a dry, flat surface, in a level position such that the enclosure is not distorted.

Screws or bolts of a minimum of 5mm diameter must be used to mount the enclosure in all three mounting positions such that the box is securely mounted and is not liable to move once fixed, and placed in an accessible position as agreed with the end user.



Once in place, all documents associated with the fire alarm or fire protection systems can be securely stored at a central point along with any keys associated with the systems for easy and reliable access.

The standard document box is 90mm deep. A 60 mm deep version is also available upon request.

Standard 003 fire alarm keys are provided to lock the box and these should be stored by the person responsible for the fire alarm systems. Spare key sets are available on request.

Specifications:

Size: $385mm(W) \times 310mm(H) \times 90mm(D)$

Construction: 1.2mm mild steel sheet

Finish: Epoxy powder coated

Colour: BS 00 A 05 grey – fine texture

Weight: 3 Kg

Lock type: 003

Document Space: A4

No of Key Spaces: 7

Mounting: Surface or Flush mount (optional with surround kit)



Sydney

Block Y, Unit 1, 391 Park Road, REGENTS PARK NSW 2143

Mail: PO Box 508 GYMEA NSW 2227

Phone: 1300 INCITE (1300 462 483) | 02 9644 7144

Fax: 02 9644 7255

Email: sales@incitefire.com.au

Technical support: support@incitefire.com.au

Melbourne

Address: Unit 120, 45 Gilby Road, MT WAVERLEY VIC 3149

Phone: 03 9544 2211 Fax: 03 9544 2212

Email: salesvic@incitefire.com.au

Brisbane

Address: 25 Jeays Street, BOWEN HILLS QLD 4006

Phone: 07 3252 5366 Fax: 07 3252 4099

Email: salesqld@incitefire.com.au

Perth

Address: Unit 2, 48 Irvine Drive, MALAGA WA 6090

Phone: 08 9349 2972

Email: saleswa@incitefire.com.au