

ESPintelligent CHQ-MRC(SCI)

Analogue Mains Relay Controller

Features

- ▶ Loop powered
- ▶ Single loop address
- ▶ Single mains rated relay contact
- ▶ Relay Contact Rated at 250 VAC @ 5 A (resistive) & 48 VDC @ 2 A (resistive)
- ▶ Auxiliary monitored input
- ▶ Features an integral short-circuit isolator
- ▶ Approved to AS ISO 7240.17 & 18



Description

Model CHQ-MRC(SCI) is a Single Input/Output Module, which provides a single, mains-rated relay output for the control of such devices as dampers, extractors or plant and equipment shutdown. The monitored input can be

used for local power supply fault monitoring or as a general-purpose input. The unit features an integral short-circuit isolator and utilises simple DIL switches for reliable addressing.

Specification

Ordering code	CHQ-MRC(SCI) - Module	CHQ-MRC/DIN(SCI) - DIN Module	
Operating voltage	17 – 41 VDC		
Low power mode (0.75s)	100 μ A		
Quiescent current (typ)	300 μ A		
Current consumption	22 mA \pm 20 % (polling)		
Current in short circuit	8 mA		
Maximum short circuit current	1 A		
Relay contact rating* **	48 VDC max, 2 A (resistive load), 250 VAC max, 5 A (resistive load) – For mains ac switching, the Control Panel must be compliant with Low Voltage Directive for SELV circuits.		
Input EOL resistor	10 k Ω , \pm 5%, 0.25 W		
Input threshold level	ON=470 Ω , Short cct <50 Ω , Open cct >100 K Ω		
Storage / Operating temperature range	-30 $^{\circ}$ C to +60 $^{\circ}$ C / -10 $^{\circ}$ C to +50 $^{\circ}$ C		
Maximum humidity	95% RH non-condensing (at 40 $^{\circ}$ C)		
Weight (g) Dimensions (mm)	Module	360 (add 235 to module weight when using CHQ-BACKBOX)	L157 x H127 x H35 (Module plus Lid) H79 (CHQ-Module plus Lid plus CHQ,BACKBOX)
	DIN Module	145	L119 x H108 x D24
Colour / Material	CHQ Module & CHQ-BACKBOX White ABS, DIN Module Green ABS, Module Lid Semi-Opaque Black ABS as standard (white version – CHQ-LID(WHT) also available)		

* Fire alarm control panel compatibility required for these products.

** No fuses are fitted on this device. The relay output circuit must therefore be protected by a suitable over-current protection device to prevent excessive current through the relay contacts. Refer to the relay contact specification in this document.