



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3813</b>	2-Jun-2023	Number 4	Issue date 12-Mar-2025	30-Apr-2026

Page 1 of 2

## Product designation

**Hochiki, Model CHQ-SIM, single Input module**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Hochiki Australia Pty Ltd  
Block Y, Unit 1 Regents Park Estate, 391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

## Registrant

Hochiki Australia Pty Ltd  
Block Y, Unit 1 Regents Park Estate, 391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

### Producer

Hochiki Europe (U.K.) Ltd  
Grosvenor Road, Gillingham Business Park, GILLINGHAM, KENT, UNITED KINGDOM, ME8 0SA

## Conformance criteria and evaluation

The Hochiki, Model CHQ-SIM, single Input module has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS ISO 7240.18:2015, 'Fire detection and alarm systems - Part 18: Input/output devices'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. This product is specified by the Producer for connection and use only with Fire Detection Control and Indicating Equipment (FDCIE) produced and designated as follows.
  - Kentec Electronics Ltd: Taktis, Syncro AS

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kai Loh  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 3813</b>	2-Jun-2023	Number 4	Issue date 12-Mar-2025	30-Apr-2026

Page 2 of 2

## Producer's description

The Hochiki, Model CHQ-SIM, single Input module provides a single monitored input to be connected to the ESP loop. The CHQ-SIM module is supplied with a protective outer casing.

The CHQ-SIM module feature flying leads as well as a wiring terminal block for loop connection. The unit is addressed with the TCH-B200 Hand Help Programmer utilising the onboard programming connector and PL-3 lead.

## Technical specification

The following details are a representative extract of the technical specification for the Hochiki, Model CHQ-SIM, single Input module and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		Description
Type	Ident.	
Model	CHQ-SIM	Single input module

### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

	CHQ-SIM
Operating voltage:	17 – 41 Vd.c.
Quiescent current:	150 µA (at 41V)
Input ratings:	
Open circuit:	>100 kΩ
Normal state:	10 kΩ
Input activation:	470 Ω
Short circuit:	<50 Ω
Operating temperature range:	-10 °C to 50 °C
Storage temperature range:	-20 °C to 60 °C
Max humidity:	95% RH non condensing
Colour / Case material	Ivory / ACS
Dimensions – length × width × depth:	65 mm × 42 mm × 15 mm
Weight:	26 g

## Supplementary information

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference		Title / description	Date issued (or date validated)	Source
Ident. type	Ident.			
Report	XF3105/R1	Evaluation for Conformity of the Hochiki, Model CHQ-POM, Powered Output Module, Model CHQ-SIM, Single Input Module, and Model CHQ-SOM, Single Output Module to the requirements of AS ISO 7240.18:2015	27-Sep-2018	CSIRO, Fire Systems Laboratory, AU
Specification	CHQ-SIM_HAU_Specification.pdf	ESPIntelligent CHS-SIM SINGLE INPUT MODULE ISS1 SEP19 (CHQ-SIM_HAU_Specification.pdf)	5-Jun-2023	Hochiki Europe (UK) Ltd, UK