



# Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2262</b>	12-Nov-2008	Number 19	Issue date 2-Apr-2024	30-Apr-2025

## Product designation

**KAC, MCP1 to MCP4 series, indoor conventional manual call points**

(Refer to the Schedule/enclosures for further specified details)

## Agent/distributor

Pencon Controls Australia Pty Ltd  
Unit 15, 65-75 Captain Cook Drive, CARINGBAH, NSW, AUSTRALIA, 2229

## Registrant

KAC Alarm Company Limited  
Honeywell House, Skimped Hill Lane, BRACKNELL, BERKS, UNITED KINGDOM, RG12 1EB

### Producer

Honeywell Life Safety Romania S.R.L.  
Strada Salcâmului nr. 2 bis, LUGOJ, ROMANIA, 305500

## Conformance criteria and evaluation

The KAC, MCP1 to MCP4 series, indoor conventional manual call points have been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. European Standard EN 54-11(Type A):2001, 'Fire detection and fire alarm systems. Manual call points'.

## Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this actuating device with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh  
Executive Officer – ActivFire Scheme



# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2262</b>	12-Nov-2008	Number 19	Issue date 2-Apr-2024	30-Apr-2025

Page 2 of 3

## Producer's description

The KAC, MCP1 to MCP4 series, indoor conventional manual call points consist of a square shaped housing within which is fitted a call point unit. The device is made up of a switch contact and the frangible element. Direct alarm activation is achieved by breaking the glass plate (frangible element) situated in the operating face of the unit or pushing the plastic resettable element. By replacing the frangible element a push button is setback into position and the device is returned to its quiescent state.

The models are as follows:

### **MCP1 models**

Red, Type A, non-addressable, break glass manual call point. The internal PCB allows for the factory fitting of various resistor and diode combinations, to ensure maximum compatibility with the greatest number of non-addressable fire alarm panels. The terminal arrangement also allows the end user access to a clean, normally open contact. Flush and surface mounting options. The MCP can be converted to a resettable model by substituting the glass for a resettable frangible element. Terminations are made via a 4 way terminal plug.

#### **MCP1A-Rxxxxx**

Normally open contact with series monitoring resistor.

#### **MCP1B-Rxxxxx**

Normally open contact with series resistor and diode (Sawwire Model)

(xxxxx represents the characters used to indicate resistor value, surface or flush mount, glass or resettable element).

### **MCP2 models**

Red, Type A, non-addressable, break glass, manual call point with forward facing 5mm diameter LED. The internal PCB allows for the factory fitting of various resistor and diode combinations, to ensure maximum compatibility with the greatest number of non-addressable fire alarm panels. The terminal arrangement also allows the end user access to a clean, normally open contact. Flush and Surface mounting options. The MCP can be converted to a resettable model by substituting the glass for a resettable frangible element. Terminations are made via a 4 way terminal plug.

#### **MCP2A-Rxxxxx**

Normally open contact with series monitoring resistor and LED network.

#### **MCP2B-Rxxxxx**

Normally open contact with series monitoring resistor, LED and diode network. (Sawwire with LED)

(xxxxx represents the characters used to indicate resistor value, surface or flush mount, glass or resettable element).

### **MCP3 models**

#### **MCP3A-Rxxxxx**

Red, Type A, non-addressable, break glass, manual call point for indoor use, providing single pole changeover contacts. Flush and surface mounting options. The MCP can be converted to a resettable model by substituting the glass for a moulded resettable frangible element. Terminations are made via a 4 way terminal plug.

(xxxxx represents the characters used to indicate resistor value, surface or flush mount, glass or resettable element).

### **MCP4 models**

#### **MCP4A-Rxxxxx**

Red, Type A, non-addressable, break glass, manual call point providing double pole changeover contacts. Flush and surface mounting options. The MCP can be converted to a resettable model by substituting the glass for a resettable frangible element. Terminations are made via a 4 way terminal plug.

(xxxxx represents the characters used to indicate resistor value, surface or flush mount, glass or resettable element).

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
<b>afp - 2262</b>	12-Nov-2008	Number 19	Issue date 2-Apr-2024	30-Apr-2025

Page 3 of 3

## Technical specification

The following details are a representative extract of the technical specification for the KAC, MCP1 to MCP4 series, indoor conventional manual call points and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Operating voltage:	30 Vdc
Current consumption:	2 A max.
Operating temperature range	-10° to 55° C
Physical characteristics	
Height	93 mm
Width	89 mm
Depth	
Flush mounted	27.5 mm
Surface mounted	59.5 mm
Colours	Red (Ral 3001), Yellow (Ral 1006), Green (Ral 6016), White (Ral 9010), Blue (Ral 5002)
Reference technical data sheet	D700 issue 9