



CSIRO Verification Services Clayton, Victoria, Australia +61 13 0036 3400 https://activfire.csiro.au

Certificate of Conformity

| | | | | • | |
|------------------|-------------------|--------|-------------|-------------|-------------|
| Certificate num. | Registration date | V | /ersion | Valid until | |
| afp - 3295 | | Number | Issue date | 22.1. 2225 | Page 1 of 3 |
| | 17-Jul-2018 | 7 | 13-Mar-2025 | 30-Apr-2026 | 5 |
| | | | | | |

Product designation

Redback, Model CF0715/CF0716, type A, indoor, surface mount, emergency sound-system loudspeaker

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Registrant

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

> Producer Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

Conformance criteria and evaluation

The Redback, Model CF0715/CF0716, type A, indoor, surface mount, emergency sound-system loudspeaker has been evaluated and verified as conforming with the relevant requirements of the following criteria.

Australian Standard AS ISO 7240.24:2015, 'Fire detection and alarm systems - Part 24: Sound-1. system loudspeakers'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

scope of CSIRO Verification Services - Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

This certification is issued within the

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with

relevant evidence.

- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services

Issued by

Kai Loh Executive Officer – ActivFire Scheme





This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time. The validity and authenticity of this certificate can be verified by the certification register located at https://activfire.csiro.au

Schedule to Certificate of Conformity

| Certificate num. | Registration date | Version | | Valid until | |
|------------------------|-------------------|--------------------|---------------------------|-------------|---------------------------|
| afp - 3295 17-Jul-2018 | | Number 7 | Issue date 13-Mar-2025 | 30-Apr-2026 | Page 2 of 3 |
| | | | | | |

Producer's description

The Redback, Model CF0715/CF0716, type A, indoor, surface mount, emergency sound-system loudspeaker is a speaker intended to provide emergency warning audible broadcasts either for indoor applications.

The loudspeaker variants differ according to the following:

- CF0715 white housing and grill
- CF0716 black housing and grill

This equipment is fitted with a speaker driver rated for a maximum power output of 5 W when provided with an input signal of 100 Vac. Five taps are provided on the included transformer for operating at a range of output levels.

The Redback, Model CF0715/CF0716, type A, indoor, surface mount, emergency sound-system loudspeaker is provided with a surface-mount cylindrical housing, resulting in an assembly approximately 310 mm in diameter and 85 mm high.

This is a type A loudspeaker intended for indoor applications only.

Technical specification

The following details are a representative extract of the technical specification for the Redback, Model CF0715/CF0716, type A, indoor, surface mount, emergency sound-system loudspeaker and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

| Variant | | | |
|---------|--------|---|-------------------------|
| Туре | Ident. | Description | Colour |
| Madal | CF0715 | Type A, indoor, flush-mount, emergency sound-system | White housing and grill |
| Model | CF0716 | loudspeaker | Black housing and grill |

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

| Rated noise power | 5 Watts (100V line) |
|------------------------------------|---|
| Power taps & impedance (100V line) | 0.33W (30kΩ), 0.66W (15kΩ), 1.25W (8kΩ), 2.5W (4kΩ), 5W (2kΩ) |
| Sensitivity | 93dB (1W@1M), 81dB (1W@4M) |
| Maximum sound pressure level | 101dB (5W@1M), 89dB (5W@4M) |
| Frequency response | 100 Hz - 15kHz; 500 - 4kHz 0 ± 8dB |
| Coverage angle (-6dB) | 500 Hz: > 180° , 1000Hz: 81° , 2000Hz: 93° , 4000Hz: 58° |
| Environmental type | A (for indoor applications as per standard) |
| Speaker component | 200mm (8") paper cone speaker |
| Mounting method | Surface attachment |
| Line monitoring | Yes, 22µF bipolar capacitor |
| Applicable cable | 2.5 mm ² (14AWG) max conductor area |
| Connection | 4 way screw terminal |
| | White (CF0715) flame retardant ABS grille and housing (Taitalac 8540T), |
| Finish | Black (CF0716) grill + housing (Starex VH-0800) |
| | Black Flame retardant ABS spring clips (Cycoloy C2950HF) |
| IP rating | IP 21C |
| Dimensions | 310 Ø x 85mm |
| Weight | 1.36kg |

Schedule to Certificate of Conformity

| Certificate num. | Registration date | V | /ersion | Valid until | |
|------------------|-------------------|-------------|---------------------------|-------------|---------------------------|
| afp - 3295 | 17-Jul-2018 | Number 7 | Issue date 13-Mar-2025 | 30-Apr-2026 | Page 3 of 3 |
| | | / | 13-IVId1-2025 | · | |

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

| Reference | | | Date issued | | |
|-------------|-----------|---|---------------------|--|--|
| ldent. type | Ident. | Title / description | (or date validated) | Source | |
| Report | XF2980/R3 | Evaluation for Conformity of the Redback, Model CF0715/CF0716, type A, indoor, surface- mount, emergency sound-system loudspeaker to the requirements of AS ISO 7240.24:2015 | 7-Mar-2018 | CSIRO, Fire Systems Laboratory, AU | |
| Data Sheet | CF0715 | Redback Data Sheet Data Sheet CF0715 200mm (8") 100V 5W FIRE Speaker White AS ISO7240.24 CF0716 200mm (8") 100V 5W FIRE Speaker Black AS ISO7240.24 CF0715 data sheet.pdf | 22-Feb-2018 | Altronic Distributors Pty Ltd, WA, AU | |