



# **Certificate of Conformity**

 Certificate num.
 Registration date
 Version
 Valid until

 afp - 3564
 19-Feb-2021
 Number 4 13-Mar-2025
 13-Mar-2025
 30-Apr-2026

### **Product designation**

Redback, Model CF0720/CF0721, type A, indoor, surface mount, emergency sound-system loudspeaker

(Refer to the Schedule/enclosures for further specified details)

#### Agent/distributor

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

#### Registrant

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

#### **Producer**

Altronic Distributors Pty Ltd 174 Roe Street, PERTH, WA, AUSTRALIA, 6000

#### Conformance criteria and evaluation

The Redback, Model CF0720/CF0721, type A, indoor, surface mount, emergency sound-system loudspeaker has been evaluated and verified as conforming with the relevant requirements of the following criteria.

 Australian Standard AS ISO 7240.24:2015, 'Fire detection and alarm systems - Part 24: Soundsystem loudspeakers'.

#### Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices. and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

ssued by

Kaj Loh

Executive Officer – ActivFire Scheme





# Schedule to Certificate of Conformity

Certificate num.	Registration date	V	ersion	Valid until	
afn - 3564	19-Feb-2021	Number	Issue date	30-Apr-2026	Page <b>2</b> of <b>3</b>
afp - 3564	19-F60-2021	4	13-Mar-2025	30-Apr-2026	

### **Producer's description**

The Redback, Model CF0720/CF0721, type A, indoor, surface mount, emergency sound-system loudspeaker is a speaker intended to provide emergency warning audible broadcasts either for indoor applications.

The loudspeaker variants differ according to the following:

- CF0720 white housing and grill
- CF0721 black housing and grill

This equipment is fitted with a speaker driver rated for a maximum power output of 5 W when provided with an input signal of 100 Vac. Five taps are provided on the included transformer for operating at a range of output levels.

The Redback, Model CF0720/CF0721, type A, indoor, surface mount, emergency sound-system loudspeaker is provided with a surface-mount cylindrical housing, resulting in an assembly approximately 310 mm in diameter and 85 mm high.

This is a type A loudspeaker intended for indoor applications only.

#### **Technical specification**

The following details are a representative extract of the technical specification for the Redback, Model CF0720/CF0721, type A, indoor, surface mount, emergency sound-system loudspeaker and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

#### Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant			
Туре	Ident.	Description	Colour
Model	CF0720	Time A indeed surface manual anapagan count analysis	White housing and grill
	CF0721	/pe A, indoor, surface-mount, emergency sound-system loudspeaker	Black housing and grill

#### Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Rated noise power	15 Watts (100V line)		
Power taps & impedance (100V line)	1.25W (8kΩ), 2.5W (4kΩ), 5W (2kΩ), 10W (1kΩ), 15W (668Ω)		
Sensitivity	96dB (1W @ 1m), 84dB (1W @ 4m)		
Maximum sound pressure level	107dB (15W @ 1m), 95dB (15W @ 4m)		
Frequency response	100Hz - 15kHz; 500-4kHz: 0±8dB		
Coverage angle (-6dB)	500Hz: > 180°, 1000Hz: 68°, 2000Hz: 96°, 4000Hz: 55°		
Environmental	Type A (for indoor applications as per standard)		
Speaker component	200mm (8") paper cone speaker		
Mounting method	Surface attachment		
Line monitoring	Yes, 22µF bipolar capacitor		
Applicable cable	2.5mm <sup>2</sup> (14AWG) max conductor area		
Connection	4 way screw terminal		
Finish	White (CF0720) flame retardant ABS grille and housing (Taitalac 8540T), Black (CF0721) grill + housing (Starex VH-0800) Black flame retardant ABS spring clips (Cycoloy C2950HF)		
IP rating	IP 21C		
Dimensions	310Ø x 85 mm		
Weight	2 kg		

# Schedule to Certificate of Conformity

Certificate num.	Registration date	Version		Valid until	
afp - 3564	19-Feb-2021	Number <b>4</b>	Issue date 13-Mar-2025	30-Apr-2026	Page <b>3</b> of <b>3</b>

## **Supplementary information**

### Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference			Data issued		
Ident. type	Ident.	Title / description	Date issued (or date validated)	Source	
Report	XF2980/R5	Evaluation for Conformity of the Redback, Model CF0720/CF0721, type A, indoor, surface-mount, emergency sound-system loudspeaker to the requirements of AS ISO 7240.24:2015	17-Feb-2020	CSIRO, Fire Systems Laboratory, AU	
Data Sheet	CF0720	Redback Data Sheet CF0720 200mm (8") 100V 15W FIRE Speaker White AS ISO7240.24 CF0721 200mm (8") 100V 15W FIRE Speaker Black AS ISO7240.24 CF0720 data sheet 30-01-19.pdf	30-Jan-2019	Altronic Distributors Pty Ltd, WA, AU	