



CSIRO Verification Services Clayton, Victoria, Australia +61 13 0036 3400 https://activfire.csiro.au

Certificate of Conformity

Registration date Valid until Certificate num. Version Number Issue date Page 1 of 2 afp - 2720 14-Feb-2012 30-Apr-2026 14 2-Apr-2024

Product designation

Hochiki, Model DFJ-C3, Class CS, heat detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Hochiki Australia Pty Ltd

Block Y, Unit 1 Regents Park Estate, 391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

Registrant

Hochiki Australia Pty Ltd

Block Y, Unit 1 Regents Park Estate, 391 Park Road, REGENTS PARK, NSW, AUSTRALIA, 2143

Producer

Hochiki Corporation

10 - 43, Kamiosaki 2-Chome, SHINAGAWA-KU, TOKYO, JAPAN, 141

Conformance criteria and evaluation

The Hochiki, Model DFJ-C3, Class CS, heat detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

Australian Standard AS ISO 7240.5:2018, 'Fire detection and alarm systems - Part 5: Point-type 1. heat detectors'.

Limitations/conditions of conformance


Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

Compatibility of this fire detector and its base assembly with new or existing control and i. indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services - Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.



Kaj Loh Executive Officer – ActivFire Scheme



This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time. The validity and authenticity of this certificate can be verified by the certification register located at https://activfire.csiro.au

© CSIRO Australia, 2024

Schedule to Certificate of Conformity

Certificate num.	Registration date	Ve	ersion	Valid until	
afp - 2720	14-Feb-2012	Number 14	Issue date 2-Apr-2024	30-Apr-2026	Page 2 of 2

Producer's description

The Hochiki, Model DFJ-C3, Class CS, heat detector is a 90°C Fixed Temperature Heat Detector using a thermistor and linearising circuit to provide an accurate linear response heat detector. A third terminal provides integral remote indicator output.

This device is ideal for use where medium ambient temperatures exist, such as in drying rooms or where smoke detectors are unsuitable because of the presence of steam or cooking fumes such as in a kitchen.

The Hochiki, Model DFJ-C3, Class CS, heat detector is supported by a wide range of bases for different applications, and these are supported on the majority of conventional systems.

Technical specification

The following details are a representative extract of the technical specification for the Hochiki, Model DFJ-C3, Class CS, heat detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant		riant		
	Туре	Ident.	Description	Compatible bases
	Model	del DFJ-C3 Class CS heat detector		YBN-R/6(White), YBO-R/6PA(White),
				YBO-R/6SK(White), YBO-R/6RN (White), YBO-R/6RS

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Operating voltage:	9.5 – 30 Vdc
Quiescent current (typ):	35 μΑ
Maximum current in alarm (typ):	80 mA
Remote indicator drive:	20 mA (max) / 9.5-14 mA (typ)
Operating temperature range:	-10 °C to +50 °C
Storage temperature range:	-30 °C to +70 °C
Maximum humidity:	95%RH - non condensing (at 40 °C)
Ingress protection rating:	IP63
Colour / Case material:	White / Polycarbonate
Weight / Diameter / Height:	76 g / 100 mm / 38 mm
Base fixing centres:	48 ~ 74 mm

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference			Date issued	
ldent. type	ldent.	Title / description	(or date validated)	Source
Report	CSBA0085/R1	Evaluation for Conformity of the Hochiki DFJ-A3 and DFJ-C3 Heat Detectors to the requirements of AS ISO 7240.5:2018	22-Mar-2024	CSIRO, Fire Systems Laboratory, AU
Specification	DFJ- C3_Specification. pdf	Hochiki Conventional Fixed Temperature Heat Detector (90 °C) DFJ-C3 (DFJ-C3_Specification.pdf)	13-Apr-2017	Hochiki Australia Pty Ltd, AU