# incite fire

# **Data sheet**

# SEC-SIM-35

Serial Interface Module

From production version 190615 and FW version 02.02.00 Firmware versions: • ASD 531/532 from 01.00.00 from 01 04 00 ASD 535

- ADW 535 from 01.01.11

The SIM 35 is an additional module for networking ASD or ADW special fire detectors.

# Description

The SIM 35 serial interface module is for networking multiple ASD or ADW special fire detectors via RS485 bus. Using the "ASD / ADW Config" configuration software, all ASD or ADW units present in the network can be visualised and operated from a PC. The SIM 35 provides galvanic separation between the RS485 interface and the special fire detectors.

# Mounting / Installation

There are four expansion slots for mounting the optional additional modules in the detector housing of the ASD 535.

In the mounting set of the SIM 35 there are module holders, retainer screws and the connection cable for connecting to the AMB 35.

The SIM 35 interface module is connected by means of the 16-pin ribbon cable to connector Option2 (or Option1). It must be ensured that the flat ferrite cores on the ribbon cable are on the AMB side (see Fig. 2).




Fig. 2 Installation of the SIM 35




Fig. 3 Connecting the SIM 35 in the ASD 535



Fig. 1 SEC SIM 35

# **Design of the network**

An network can have up to 250 participants. The master module in the network is the SMM 535, by means of which a PC is connected.



The normative alarm transmission of the special fire detector to the higher level point does not use the network. The "Alarm" / "Fault" relays in the special fire detector or SecuriLine (SLM 35) are used for that.




Fig. 4 Design of the ASD network

- 1) Screen with equipotential bonding connected, always only on the SMM 535, do not connect on the last SIM 35; 3).
- 2) Screen connected by means of a lustre terminal.
- 3) If SMM 535 is in the network, do not connect the screen on the first and last SIM 35 (beginning and end).
- 4) Network cable: 4-core, twisted / screened (only 3 wires are used, total length max. 1.000 m).
- 5) USB cable; max. 3 m in length.
- C) There must be bus termination on both sides of the network (beginning and end); jumper "TERM", position "C".

#### Programming

Jumper TERM	Bus termination (position "C" = active)				
Position <b>O</b>	SIM 35 is <u>not</u> first or last module				
Position C	SIM 35 is <u>first</u> or <u>last</u> module				
Jumper BOOT MODE	FW upgrade (not equipped, needed only for production)				
Position R	Normal position				
Position P	Local FW upgrade on the SIM 35				
Button RESET	SIM reset				
Press	Triggers a HW reset of the SIM 35				

incite fire

#### **Network address**

Each SIM 35 or special fire detector is assigned its own address. They are assigned based on the wiring topology **ascending** (see also **Fig. 4**).

The SIM 35 has two rotary switches (S1 and S2) for setting the network address in hexadecimal code. Setting the hexadecimal codes is shown in the table below.

Rotary switch S1 / S2 Network address in hexadecimal code															
Dec	S2 Hex	Dec	Hex SS	Dec	Hex SS	Dec	Hex SS	Dec	Hex SS S	Dec	Hex 55 55	Dec	Hex SS	Dec	He) 5.0
0	0, 0,	32	2 0	64	4 0	96	6 0	128	8 0	160	A 0	192	C 0	224	EO
1	0.1	33	21	65	41	97	61	129	81	161	A 1	193	<u>C 1</u>	225	E 1
2	0 2	34	2 2	66	4 2	98	62	130	8 2	162	A 2	194	C 2	226	E 2
3	03	35	23	67	43	99	63	131	83	163	A 3	195	C 3	227	E 3
4	04	36	24	68	4 4	100	64	132	84	164	A 4	196	C 4	228	E 4
5	05	37	2 5	69	45	101	65	133	85	165	A 5	197	C 5	229	E 5
6	06	38	26	70	46	102	66	134	86	166	A 6	198	C 6	230	E 6
7	07	39	27	71	47	103	67	135	87	167	Α7	199	C 7	231	E 7
8	08	40	28	72	48	104	68	136	88	168	A 8	200	C 8	232	E 8
9	09	41	29	73	49	105	69	137	89	169	A 9	201	С 9	233	E 9
10	0 A	42	2 A	74	4 A	106	6 A	138	8 A	170	ΑA	202	СΑ	234	ΕA
11	0 B	43	2 B	75	4 B	107	6 B	139	8 B	171	ΑB	203	СΒ	235	ΕB
12	0 C	44	2 C	76	4 C	108	6 C	140	8 C	172	ΑC	204	СС	236	ΕC
13	0 D	45	2 D	77	4 D	109	6 D	141	8 D	173	ΑD	205	СD	237	ΕD
14	0 E	46	2 E	78	4 E	110	6 E	142	8 E	174	ΑE	206	СЕ	238	ΕE
15	0 F	47	2 F	79	4 F	111	6 F	143	8 F	175	ΑF	207	CF	239	ΕF
16	10	48	30	80	50	112	70	144	90	176	Β0	208	D 0	240	F 0
17	11	49	31	81	51	113	7.1	145	91	177	В1	209	D 1	241	F 1
18	1 2	50	32	82	52	114	72	146	92	178	В2	210	D 2	242	F 2
19	13	51	33	83	53	115	73	147	93	179	В3	211	D 3	243	F 3
20	14	52	34	84	54	116	74	148	94	180	В4	212	D 4	244	F 4
21	15	53	35	85	55	117	75	149	95	181	B 5	213	D 5	245	F 5
22	16	54	36	86	56	118	76	150	96	182	B 6	214	D 6	246	F 6
23	17	-55	37	87	57	119	77	151	97	183	В7	215	D 7	247	F 7
-24	18	-56	38	88	58	120	78	152	98	184	B 8	216	D 8	248	F 8
25	19	57	39	89	59	121	79	153	99	185	В9	217	D 9	249	F 9
26	1 A	-58	3 A	90	5 A	122	7 A	154	9 A	186	ΒA	218	DΑ	250	FΑ
27	1 B	59	3 B	91	5 B	123	7 B	155	9 B	187	ΒB	219	DВ		
28	1 C	60	3 C	92	5 C	124	7 C	156	9 C	188	ВC	220	DС		
-29	1 D	61	3 D	93	5 D	125	7 D	157	9 D	189	ВD	221	DD		
-30	1 E	62	3 E	94	5 E	126	7 E	158	9 E	190	ΒE	222	DΕ		
31	1 F	63	3 F	95	5 F	127	7 F	159	9 F	191	ΒF	223	DF		

# **Dimensioned drawing**




Fig. 5 SIM 35 dimensioned drawing

#### Indicators

Four LEDs on the SIM 35 indicate the operating state.

LED	State / meaning							
PG (green)	continuously lit, power supply from AMB/LMB OK							
PGI (green)	<b>continuously lit</b> , supply voltage OK (after gal- vanic separation)							
COM (green)	flashes, communication running, "ASD / ADW Config" is active							
ERR (yellow)	flashes, address is in invalid range; continuously lit, SIM has a fault							

# **Terminal assignment**

Terminal	Signal	Installatio
----------	--------	-------------

renninai	Olgilai	mstanation			
1	GND	ıt	1 <sup>st</sup> conductor from wire pair 2		
2	D +	ndu	1 <sup>st</sup> conductor from wire pair 1	- twisted	
3	D –	I	2 <sup>nd</sup> conductor from wire pair 1	Iwisted	
4	GND	ut	1 <sup>st</sup> conductor from wire pair 2		
5	D +	utp	1 <sup>st</sup> conductor from wire pair 1	twisted	
6 D –		0	2 <sup>nd</sup> conductor from wire pair 1	- twisted	

Connection of screening, see Fig. 4.

#### Article numbers / Spare parts

Brief description	Article number
SIM 35, incl. mounting set	11-2200000-01-XX
Technical Description ASD 532	T 140 421
Data sheet ASD 532	T 140 422
Technical Description ASD 535	T 131 192
Data sheet ASD 535	T 131 193
Technical Description ADW 535	T 140 358
Data sheet ADW 535	T 140 359
Data sheet SMM 535	T 140 010

# **Technical data**

Туре	SIM 35	
Operating voltage from AMB 35	5	VDC
Maximum power consumption	20	mA
Ambient conditions acc. to IEC 721-3-3 / EN 60721-3-3 (1995)	3K5 / 3Z1	Class
Extended ambient conditions:		
SIM 35 temperature range	-30 - +70	°C
<ul> <li>Max. permitted storage temperature (without condensation)</li> </ul>	-30 - +70	°C
Humidity ambient condition (transient without condensation)	95	% rel. hum.
Humidity ambient temperature (continuous)	70	% rel. hum.
Plug-in terminals	2.5	mm²
Cable type: 4-core, twisted in pairs, screened, impedance 120R	at least 0.2	mm²
maximum line length of the entire network	1,000	m
Dimensions (W x H x D)	95 x 58 x 17	mm
Weight (including module holder)	55	g